

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRRES20161381, Building Permit - Residential  
Address: 3123 SE 3RD TER, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Service Inspection - Residential</b>	Mike Copeland	Failed	Thursday, December 08, 2016

Corrective Action Required

1	Misc 1	NO PRESSURE
---	--------	-------------

<b>Electrical Service Inspection - Residential</b>	Mike Copeland	Passed	Thursday, December 08, 2016
--	---------------	--------	-----------------------------

<b>All Rough Inspection - Residential</b>	Mike Copeland	Failed	Thursday, December 08, 2016
---	---------------	--------	-----------------------------

Corrective Action Required

1	Misc 1	-REPLACE CUT I JOIST IN BASEMENT EAST END, CUT FOR PLUMBING -SECURITY BLOCK REAR DOOR -NM CONDUCTORS 6 FEET FROM ATTIC ACCESS, NEED TO BE SECURED TO THE RUNNING BOARD IN ORDER TO PROTECT THE CONDUCTORS. -INSTALL STUD SUPPORT FOR GIRDER TRUSS MASTER CLOSET AT WEST END AND NAIL THE TOP CHORDS OF THE GIRDER.
---	--------	---

OKAY TO INSULATE

**Comments:**