

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161178, Building Permit - Commercial
Address: 1800 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	John Borns	Partial	Monday, December 12, 2016

Partial Correction

1 Misc 1

OK TO COVER WHEN READY UNDER-SLAB PVC SANITARY DRAIN, WASTE, & VENT PIPING AT:FROM WEST END EAST TO 6" BLDG DRAIN + 6" SOUTH TO UNDER FOOTING; REMAINDER OF PVC UNDER-SLAB DWV EXCEPT LINES TO POOL & EMPLOYEE RR;

NOTE IPC 312 / IRC P2503.5.1 REQUIREMENT FOR PRESSURE-TESTING PIPING SYSTEM.

Partial Correction

2 Misc 1

OK TO COVER WHEN READY UNDER-SLAB C.I. GREASE WASTE PIPING COMPLETE

Underslab Electrical Inspection - Commercial	John Borns	Partial	Monday, December 12, 2016
---	------------	---------	---------------------------

Partial Correction

1 Misc 1

OK TO COVER WHEN READY: ONE 3" PVC DATACOMM CONDUIT AT WEST END OF BLDG; **TWO 3" PVC CONDUITS W>E ACROSS LENGTH OF BLDG COMPLETE TO ELECTRICAL ROOM; FIVE 4" +**

**TWO 3" PVC CONDUITS FROM ELECT RM E/SE/S TO THROUGH
GRADE BEAM AT S WALL; THREE 1" CONDUITS STUBBED
THROUGH GRADE BEAM AT S WALL;**

Comments: