

**PLANNING AND CODES ADMINISTRATION DEPARTMENT**  
**220 SE GREEN STREET**  
**LEE'S SUMMIT, MO 64063**  
**(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20160277, Building Permit - Commercial  
Address: 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	John Borns	Partial	Tuesday, December 13, 2016
Partial Correction 2 Misc 1		OK TO COVER WHEN READY: TWELVE 3" PVC SECONDARY SERVICE CONDUITS FROM TRANSFORMER LOCATION TO BUILDING ENTRY; SIX 4" PVC BETWEEN (O) & (Q) EXTENDING 20' WEST FROM GRADE BEAM AT (2) + ADDITIONAL 40' WEST; THREE 4" PVC FROM QUAZITE BOX ES3 SOUTH COMPLETE TO QUAZITE BOX NEAR NEW BRIDGE OVER RAILROAD TRACKS	
Partial Correction 3 Misc 1		OK TO POUR WHEN READY LIGHT POLE BASES AT FOLLOWING LOCATIONS NUMBERED ON SITE PLAN IN PERMIT PRINT SET: #15; #16; #21; #17 thru #20; #22; #26; #1; #2; #3; #4; #5; #7; #10; #25; #6; #8; #9;#11;	
Partial Correction 1 Misc 1		OK TO COVER WHEN READY INSTALLATION OF BURIED SITE LIGHTING ELECTRICAL CONDUIT FOLLOWING SEGMENTS: FROM LOCATION OF LP BASE #1 TO #2 TO #3; #5 TO #6; #3 TO #4 TO #5; #6 TO #10; #10 TOWARD #11; COMPLETE TO #11 TO #12; #12 TO #13 TO #14; #1 TO [ES3] TO #27 TO 12" x 20" QUAZITE BOX & TO #26 TO #9 TO #8 TO #7; #14 TO #15; #15 THROUGH #22; #22 TO #23 TO #24 TO #25;	
<b>Underground Electrical Inspection - Commercial</b>	John Borns	Partial	Tuesday, December 13, 2016
Partial Correction			

- 1 Misc 1 OK TO COVER WHEN READY INSTALLATION OF BURIED SITE LIGHTING ELECTRICAL CONDUIT FOLLOWING SEGMENTS: FROM LOCATION OF LP BASE #1 TO #2 TO #3; #5 TO #6; #3 TO #4 TO #5; #6 TO #10; #10 TOWARD #11; COMPLETE TO #11 TO #12; #12 TO #13 TO #14; #1 TO [ES3] TO #27 TO 12" x 20" QUAZITE BOX & TO #26 TO #9 TO #8 TO #7; #14 TO #15; #15 THROUGH #22; #22 TO #23 TO #24 TO #25;
- Partial Correction  
2 Misc 1 OK TO COVER WHEN READY: TWELVE 3" PVC SECONDARY SERVICE CONDUITS FROM TRANSFORMER LOCATION TO BUILDING ENTRY; SIX 4" PVC BETWEEN (O) & (Q) EXTENDING 20' WEST FROM GRADE BEAM AT (2) + ADDITIONAL 40' WEST; THREE 4" PVC FROM QUAZITE BOX ES3 SOUTH COMPLETE TO QUAZITE BOX NEAR NEW BRIDGE OVER RAILROAD TRACKS
- Partial Correction  
3 Misc 1 OK TO POUR WHEN READY LIGHT POLE BASES AT FOLLOWING LOCATIONS NUMBERED ON SITE PLAN IN PERMIT PRINT SET: #15; #16; #21; #17 thru #20; #22; #26; #1; #2; #3; #4; #5; #7; #10; #25;

**Comments:**