

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20162108, Building Permit - Residential
Address: 1713 SW NAPA VALLEY DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mark Harding	Failed	Tuesday, December 13, 2016

Corrective Action Required

1	Misc 1	no plans on site-incomplete inspection. tie rafters over front bedroom. install plumbing protection plates where required. firestop drop ceiling and fireplace vent, fur down for fireplace vent. install garage straps. tie roof over mstr bedroom. solid blocki at firestop locations (not unfaced loose insulation) dead space at shower, rear shower, arch 1st floor etc. -tie top plates front tall wall. -fire block at kitchen hood vent.
---	--------	--

Comments: