

Temporary Certificate of Occupancy

Permit #: PRCOM20152912
Address: 2751 NE DOUGLAS ST, Unit:T, LEES SUMMIT, MO 64064
Inspected On: Tuesday, December 13, 2016
Inspected By: Khanh Nguyen Michael Weissenbach Hector Soto
Expiration Date: 1/13/2017 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Temporary C of O	Tuesday, December 13, 2016

Corrective Action Required:

1	Misc 1	-APPROVAL REQUIRED FROM: FIRE, PLANNING, PUBLIC WORKS -SUBMIT 3RD PARTY SPECIAL INSPECTION APPROVAL LETTER FOR: SOIL BEARING, CONCRETE, STEEL FRAMING, SEWER HOLDING TANK CLOSE TO THE FOOTING -SOD DISTURBED AREA -INSTALL SPLASHBLOCKS OUTSIDE -WINDOWS BY REAR DOOR MUST BE SAFTY TEMPERED WINDOWS -COMPLETE ELECTRICAL SERVICE AND ALL CIRCUITS; LIGHTS AT EXTERIOR DOORS; SECURE MC WITHIN 12" OF BOX; COMPLETE WATER SERVICE
---	--------	---

***BUILDING OK FOR AIRCRAFT STORAGE ONLY

Occupancy Inspection - Fire	Michael Weissenbach	Temporary C of O	Tuesday, December 13, 2016
Occupancy Inspection - Planning	Hector Soto	Temporary C of O	Tuesday, December 13, 2016