

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20162583, Building Permit - Commercial
Address: 20 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------|--|------------------------------|
| Underslab Plumbing Inspection - Commercial | John Borns | Partial | Wednesday, December 14, 2016 |
| Partial Correction 1 Misc 1 | | OK TO COVER WHEN READY UNDER-SLAB PVC SANITARY DRAIN, WASTE, & VENT PIPING AT: 1C122; 1D24; 1C217; 1C218; 1C218A; RELOCATED SCRUB SINK @ 1C219; 1C117; 1C121; NOTE IPC 312 / IRC P2503.5.1 REQUIREMENT FOR PRESSURE-TESTING PIPING SYSTEM. | |
| In-wall Inspection | John Borns | Partial | Wednesday, December 14, 2016 |
| Partial Correction 1 Misc 1 | | OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING LOCATIONS: 1C122 SOUTH WALL; 1C216; 1C217; CUT-IN DOOR 1C219; 1D23 NW WALL B/F; 1D25; 1D26; IN-FILL AT 1D22 N WALL B/F; 1D24 B/F; 1D25 O/SF; 1D26 W WALL B/F; 1D221 E WALL B/F; 1C223; 1C221 CONTINGENT ON SEGMENT OF CORRIDOR SMOKE WALL BEING SMOKE-SEALED; C137 E/NE WALL; B/F = BOTH FACES O/SF = OUTSIDE FACE | |
| Rated Assembly Inspection | John Borns | Partial | Wednesday, December 14, 2016 |

Partial Correction

1 Misc 1

GWB AT 1 HR FIRE-RATED WALLS: OK TO TAPE, MUD, & FIRE-SEAL WHEN READY 5/8" TYPE X GWB INSTALLATION @ FOLLOWING LOCATIONS: 1D25 & 1D26 WEST WALL; 1C133 S WALL B/F; 1D25 & 1D26 BACK FACES, CONTINGENT ON APPROVABLE FIRE-STOPPING TO BE INSPECTED WHEN READY; **N&W WALLS OF 1D24 UP TO 10' AFF B/F;**

B/F = BOTH FACES

Comments: