

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20162803, Building Permit - Commercial  
Address: 1800 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Electrical Inspection - Commercial</b>	John Borns	Partial	Wednesday, December 14, 2016

Partial Correction  
1 Misc 1

NO ISSUES FOUND ON UNDER-SLAB ELECTRICAL CONDUIT  
MATERIAL & WORKMANSHIP AT: **TWO 2" PVC UNDER ELECT RM  
FROM PANEL-TO-PANEL; TWO 4" FROM ELECT RM TO PANEL  
"K"; ONE 2" PVC FROM ELECT RM TO PANEL "K1";**

**Comments:**