

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161180, Building Permit - Commercial

Address: 501 NW SHAMROCK AVE, LEES SUMMIT, MO 64081521 NW SHAMROCK AVE, LEES SUMMIT,
MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	John Borns	Partial	Thursday, December 15, 2016

Partial Correction

1 Misc 1

OK TO POUR WHEN READY SECTIONS OF SPREAD FOOTING BETWEEN POINTS MARKED ON PERMIT PRINTS FOUNDATION PLAN: (1) CCW TO (2); (20) CW TO (19); (3) TO (4) TO (5); (5) TO (6) TO (7) TO (8) TO (9) TO (10) TO (19);

Partial Correction

2 Misc 1

OK TO POUR WHEN READY ISOLATED FOOTINGS AT FOLLOWING LOCATIONS: C/1; C/2; **B/2; B/3;**

Partial Correction

3 Misc 1

OK TO **POUR WHEN READY PIT SLAB AT SOUTH ELEVATOR @ F.8/12**

Comments: