

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20162583, Building Permit - Commercial  
Address: 20 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Electrical Inspection - Commercial</b>	John Borns	Partial	Friday, December 16, 2016

Partial Correction  
1 Misc 1

**OK TO COVER WHEN READY UNDER-SLAB ELECTRICAL CONDUIT  
& BOXES (MATERIAL & WORKMANSHIP) AT 1C218**

<b>Underslab Plumbing Inspection - Commercial</b>	John Borns	Partial	Friday, December 16, 2016
---	------------	---------	---------------------------

Partial Correction  
1 Misc 1

OK TO COVER WHEN READY UNDER-SLAB PVC SANITARY DRAIN,  
WASTE, & VENT PIPING AT: 1C122; 1D24; 1C217; 1C218; 1C218A;  
RELOCATED SCRUB SINK @ 1C219; 1C117; 1C121;

NOTE IPC 312 / IRC P2503.5.1 REQUIREMENT FOR  
PRESSURE-TESTING PIPING SYSTEM.

Partial Correction  
2 Misc 1

**OK TO COVER WHEN READY TWO COPPER LINES SLEEVED IN PVC  
IN 1C218 FROM CENTER OF ROOM TO WEST WALL**

**Comments:**