

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161178, Building Permit - Commercial
Address: 1800 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Electrical Inspection - Commercial	John Borns	Partial	Friday, December 16, 2016

Partial Correction
1 Misc 1

OK TO COVER WHEN READY: ONE 3" PVC DATACOMM CONDUIT AT WEST END OF BLDG; TWO 3" PVC CONDUITS W>E ACROSS LENGTH OF BLDG COMPLETE TO ELECTRICAL ROOM; FIVE 4" + TWO 3" PVC CONDUITS FROM ELECT RM E/SE/S TO THROUGH GRADE BEAM AT S WALL; THREE 1" CONDUITS STUBBED THROUGH GRADE BEAM AT S WALL; **CONDUIT AND BOXES AT BASE ELEVATION COMPLETE FROM (II) TO WEST END;**

Comments: