

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161918, Building Permit - Commercial
Address: 1399 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Partial	Monday, December 19, 2016

Partial Correction
2 Misc 1

OK TO COVER WHEN READY **EXTERIOR SHORT WALLS BELOW WINDOWS AT DINING AREA N/W/S -- NEW ELECTRICAL CABLE & BOXES; EXISTING FRAMING; INSULATION TO BE RESTORED**

Partial Correction
3 Misc 1

OK TO COVER WHEN READY **VERTICAL TENSION STUD FRAMING AT NEW SOFFIT AREA AT DINING AREA NE;**

Comments: