

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161179, Building Permit - Commercial
Address: 1820 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Tuesday, December 20, 2016

Partial Correction
1 Misc 1

OK TO COVER WHEN READY ONE 2" PVC CONDUIT + FOUR 4" CONDUITS FROM NE CORNER OF BLDG TO TRANSFORMER LOCATION FOR SECONDARY POWER

Comments: