
PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20161633, Public Works Infrastructure Permit - Commercial
Lee's Summit Honda Parking Addition (301 NE Colbern Rd)
Address: 301 NE COLBERN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
PW-Erosion Sediment Control (ESC) Inspection	Steve Robbins	Passed	Wednesday, December 21, 2016
PW-Storm - Inlets Clean	Steve Robbins	Passed	Wednesday, December 21, 2016
Informational			
1	All the storm inlets are clean and pass inspections.Steve Robbins 12/21/2016 2:13 PM		
PW-Grading/Excavation/Fill Inspection	Steve Robbins	Partial	Wednesday, December 21, 2016
Informational			
1	Some grading in the front by colbern rd needs to be graded better, there are also a few items by the storm basin that needs to be smoothed out a little better also.Steve Robbins 12/21/2016 2:19 PM		
PW-Storm - Swales	Steve Robbins	Passed	Wednesday, December 21, 2016

Comments:

