

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161180, Building Permit - Commercial

Address: 501 NW SHAMROCK AVE, LEES SUMMIT, MO 64081521 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	Mike Copeland	Not Ready	Thursday, December 22, 2016

Partial Correction  
1 Misc 1

OK TO POUR WHEN READY SECTIONS OF SPREAD FOOTING BETWEEN POINTS MARKED ON PERMIT PRINTS FOUNDATION PLAN: (1) CCW TO (2); (20) CW TO (19); (3) TO (4) TO (5); (5) TO (6) TO (7) TO (8) TO (9) TO (10) TO (19);

Partial Correction  
2 Misc 1

OK TO POUR WHEN READY ISOLATED FOOTINGS AT FOLLOWING LOCATIONS: C/1; C/2; B/2; B/3;

Partial Correction  
3 Misc 1

OK TO POUR WHEN READY PIT SLAB AT SOUTH ELEVATOR @ F.8/12

**Comments:**