

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20162803, Building Permit - Commercial
Address: 1800 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Mike Copeland	Partial	Thursday, December 22, 2016

Partial Correction
1 Misc 1

OK TO COVER WHEN READY BURIED CONDUIT FOR SITE ELECTRICAL SYSTEM AT FOLLOWING LOCATIONS NUMBERED ON SITE PLAN IN PERMIT PRINT SET: #1 TO #2; FROM #3 SW 90' TO NEAR STORM INLET;

Partial Correction
2 Misc 1

-SECONDARY CONDUITS SOUTH SIDE COMMONS, 5 4" AND 2 3" CONDUITS APPROVED TO COVER

Comments: