

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRRES20161381, Building Permit - Residential  
Address: 3123 SE 3RD TER, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Thursday, December 22, 2016

Corrective Action Required

1	Misc 1	-SECURITY BLOCK REAR DOOR **INSTALL BLOCKING AT STRIKE PLATE SIDE (AT STRIKE PLATE HEIGHT) AND FILL IN GAPS AT HINGES  -HAVE THE ELECTRICIAN REWIRE THE HOUSE. THE HOUSE WIRINGS WERE VANDALIZED  OKAY TO INSULATE
---	--------	---

<b>Gas Service Inspection - Residential</b>	Khanh Nguyen	Passed	Thursday, December 22, 2016
---	--------------	--------	-----------------------------

**Comments:**