

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRRES20162248, Building Permit - Residential  
Address: 1353 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Thursday, December 22, 2016

### Corrective Action Required

1 Misc 1

#### FRAMING:

-ENGINEER FLOOR JOIST PLAN SHOWS CONTINUOUS I JOISTS.  
HAVE ENGINEER ADDRESS/OK THE CANTILEVERED JOISTS  
CARRYING FLOOR LOAD OF THE GAME RM

-INSTALL HEADERS ABOVE WINDOWS PER PLAN OR HAVE  
ENGINEER ADDRESS/OK. LOOK AT HEADER ABOVE DOUBLE  
WINDOW IN BASEMENT

#### ELECTRICAL:

-COMPLETE ALL ELECTRICAL IN BASEMENT, ALL OUTSIDE  
ELECTRICAL SUCH AS LIGHTS AT EXTERIOR DOORS, RECEPTACLE  
AT REAR AND RECEPTACLE WITHIN 25 FT OF AC UNIT, FLOOD  
LIGHT, ETC

-BOND GAS PIPE

**\*\*OK TO INSULATE**

### Comments: