

**PLANNING AND CODES ADMINISTRATION DEPARTMENT**  
**220 SE GREEN STREET**  
**LEE'S SUMMIT, MO 64063**  
**(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20162583, Building Permit - Commercial  
Address: 20 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	John Borns	Partial	Tuesday, December 27, 2016

Partial Correction  
1 Misc 1

OK TO COVER WHEN READY ACT CEILING FRAMING +  
ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES: **1C216**;

<b>In-wall Inspection</b>	John Borns	Partial	Tuesday, December 27, 2016
---------------------------	------------	---------	----------------------------

Partial Correction  
1 Misc 1

OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING LOCATIONS: 1C122 SOUTH WALL; 1C216; 1C217; CUT-IN DOOR 1C219; 1D23 NW WALL B/F; 1D25; 1D26; IN-FILL AT 1D22 N WALL B/F; 1D24 B/F; 1D25 O/SF; 1D26 W WALL B/F; 1D221 E WALL B/F; 1C223; 1C221 CONTINGENT ON SEGMENT OF CORRIDOR SMOKE WALL BEING SMOKE-SEALED; C137; E/NE WALL; **1C120 & 121 B/F**;

B/F = BOTH FACES  
O/SF = OUTSIDE FACE

<b>Rated Assembly Inspection</b>	John Borns	Partial	Tuesday, December 27, 2016
----------------------------------	------------	---------	----------------------------

Partial Correction  
1 Misc 1

GWB AT 1 HR FIRE-RATED WALLS: OK TO TAPE, MUD, & FIRE-SEAL WHEN READY 5/8" TYPE X GWB INSTALLATION @ FOLLOWING LOCATIONS: 1D25 & 1D26 WEST WALL; 1C133 S WALL B/F; 1D25 & 1D26 BACK FACES, CONTINGENT ON APPROVABLE

FIRE-STOPPING TO BE INSPECTED WHEN READY; N&W WALLS OF  
1D24 UP TO 10' AFF B/F; **LINER BOARD HIGH ON WALL @ 1D24  
NE B/F;**

B/F = BOTH FACES

**Comments:**