

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20162567, Building Permit - Commercial  
Address: 789 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Electrical Inspection - Commercial</b>	John Borns	Passed	Wednesday, December 28, 2016
<b>Underground Plumbing Inspection - Commercial</b>	John Borns	Passed	Wednesday, December 28, 2016

**Comments: NO ISSUES FOUND ON UPPER LIFT UNDER-SLAB ELECTRICAL CONDUIT MATERIAL & WORKMANSHIP. G.C. AND E.C. TO ENSURE LAYOUT IS CORRECT. UFER GROUND G.E.C. LEADS EXOTHERMIC-WELDED TO RE-BAR JUMPERS. OK TO COVER WHEN READY.**

**NO ISSUES FOUND ON UNDER-SLAB DOMESTIC WATER PIPING. OK TO COVER WHEN READY.**