

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20162365, Building Permit - Commercial
Address: 813 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	John Borns	Passed	Wednesday, December 28, 2016

Comments: FOOTING POURED ON CITY HOLIDAY. INSPECTION DEFERRED BY JB TO 3RD PARTY INSPECTOR. UFER GROUND RE-BAR JUMPERS FOUND AT NE & SE CORNERS MARKED WITH DUCT TAPE.