

FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No: PRCOM20160836

TWIN LAKES INSURANCE

Location:

Project Title:

2641 NE MCBAINE DR, LEES

SUMMIT, MO 64064

Type of Work:

Occupancy Group: B

Description: NEW OFFICE BUILDING

FOUNDATION PERMIT -

PRCOM20161018

Construction Type: Type VB (Unprotected)

Map Page: 175R

Date: December 28, 2016

Applicant:

ABSOLUTE FIRE INC 13906 CENTURY LN GRANDVIEW, MO 64030

Primary: (816) 737-9991

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review Reviewed By: Joe Dir Released for Construction

- 1. Provide updated drawings showing the location of the dry system inspectors test. NW corner of the building.
- 2. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test. FIELD AND ACCEPTANCE TESTING OF THE SYSTEM WILL BE REQUIRED PRIOR TO THE FINAL OCCUPANCY INSPECTION. TO SCHEDULE A TEST CONTACT THE FIRE DEPARTMENT AT 816-969-1300.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.