

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160277, Building Permit - Commercial
Address: 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	John Borns	Partial	Thursday, December 29, 2016

Partial Correction
1 Misc 1

NO ISSUES FOUND ON VISUAL INSPECTION OF 3" GAS PIPE FROM BUILDING ENTRY TO MEZZANINE. P.C. HAS PRESSURE TEST IN PROGRESS ON 3" LINE ONLY.

Comments: