

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161179, Building Permit - Commercial
Address: 1820 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	Mike Copeland	Partial	Friday, December 30, 2016

Partial Correction
1 Misc 1

NO DETAIL FOUND FOR EXTERIOR SHEAR WALLS OR NAILING
PATTERN.
THE FIRST FLOOR WAS NAILED FLUSH IN EXCESS OF 4" ON THE
SEEMS AND 6" IN THE FIELD.

Comments: