



**LEE'S SUMMIT**  
**MISSOURI**



**FIRE DEPARTMENT**

**PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20163284	Date:	January 03, 2017
Project Title:	TEAM HOLIMAN LLC	Applicant:	
Location:	319 SE DOUGLAS ST, Unit:317, LEES SUMMIT, MO 64063	NATIONAL FIRE SUPPRESSION 501 SUNSHINE RD KANSAS CITY, KS 66115	
Type of Work:			
Occupancy Group:			
Description:	INTERIOR ALTERATIONS FOR NEW INSURANCE SALES OFFICE	Primary: (913) 321-9208	

\*drawings are in plan review file

Construction Type: Type VB (Unprotected)

Map Page: 195G

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

**Sprinkler Plan Review**

**Reviewed By: Joe Dir**

**Released for Construction**

1. 2012 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

EXISTING FIRE SPRINKLER SYSTEM SHALL BE CURRENT WITH ALL OF THE REQUIRED SERVICE AND MAINTENANCE. A CURRENT SERVICE TAG SHALL BE POSTED ON THE SYSTEMS RISER.

(VERIFIED AT INSPECTION)

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**