

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161179, Building Permit - Commercial  
Address: 1820 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Framing Inspection - Commercial</b>	John Borns	Partial	Tuesday, January 03, 2017

Partial Correction  
1          Misc 1

NO DETAIL FOUND FOR EXTERIOR SHEAR WALLS OR NAILING PATTERN.  
THE FIRST FLOOR WAS NAILED FLUSH IN EXCESS OF 4" ON THE SEAMS AND 6" IN THE FIELD.

**SOUTH ELEVATION: WARNING RE HIGH PERCENTAGE OF OVER-DRIVEN NAILS. PATTERN GENERALLY GOOD; SOME INSIDE AND OUTSIDE CORNERS TO BE FURTHER NAILED**

**Comments:**