

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160277, Building Permit - Commercial
Address: 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Not Ready	Wednesday, January 04, 2017

Partial Correction
1 Misc 1

OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING
+ IN-WALL SYSTEMS AT FOLLOWING LOCATIONS: EAST WALL OF
ELECT 3-161; OK TO 4' TOP-OUT WALLS AT RISK;

**BOCA PLATES NOT IN USE TO PROTECT PVC & COPPER PIPE AT
BOTTOM TRACKS; INSPECTION SUSPENDED AWAITING
CORRECTIONS**

Comments: