

**PUBLIC WORKS ENGINEERING DIVISION**

**Inspection Summary**

Permit #: PRPWFC20160041, Public Works Infrastructure Permit - Commercial  
Holiday Inn Express (1201 NW Innovation Pkwy.)FDP  
Address: 1201 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

<b>Inspection:</b>	<b>Inspector:</b>	<b>Outcome:</b>	<b>Date:</b>
PW-Fire Line - Hydrostatic Test	Steve Robbins	Passed	Wednesday, January 04, 2017

Informational

1 Today the hydrostatic pressure test was done 200 for 2 hrs. The test passed.Steve Robbins  
01/04/2017 3:38 PM

**Comments:**