PLANNING AND CODES ADMINISTRATION DEPARTMENT 220 SE GREEN STREET LEE'S SUMMIT, MO 64063 (816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20152438, Building Permit - Commercial Address: 3381 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Wednesday, January 04, 2017
Partial Correction 1 Misc 1		OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING LOCATIONS: ONE-SIDING OF ELECT[115]; VEST [118] N WALL TWO LAYERS S FACE; TWO 4' WIDE STACKS @ PLATFORM [117] FOR DUCTWORK; MECH [145]; WOMENS RR [103]; MEN'S RR[104]; JANITOR [105]; FAMILY RR [106]; ELECT [115] SOUTH WALL SOUTH FACE; 102 ; 129; 144;	
		SOUTH WALL OF E-W LEG OF N END OF CORR [128]; [131]-[143]; [145]; [147]-[150]; [157]; [151] THROUGH [156]; IN-WALL OK FOR: SANCTUARY 113 STARTING FROM PLATFORM (117) STAIR ALL THE WAY AROUND TO THE OTHER SIDE; RM 107 TO 112; DOUBLE STUD WALL BETWEEN 113&102	
Above Ceiling Inspection	John Borns	Partial	Wednesday, January 04, 2017
Partial Correction 1 Misc 1		OK TO COVER WHEN READY GWB CEILING FRAMING + ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES: VESTIBULE OUTSIDE RR'S 103 & 104; 157 CONTINGENT ON INSTALLATION OF SPRINKLER DROP & S.A. DIFFUSER + REMOVAL OF TEMP WIRING;	
Rough Framing	John Borns	Partial	Wednesday, January 04, 2017

rrection	
Misc 1	OK TO COVER WHEN READY L.G. STEEL FURRING FRAMING PER WALL SECTION 1/E1 ON ERECTION DRWG. TAPCON FASTENING APPROVED PER DETAIL 4/S4.01.
prrection	-RAISED FLOOR FRAMING UNDER RM 121-127; SAME AT 120;
Misc 1	SOUTH WALL OF 120 OK FOR CONSTRUCTION OF ADJACENT RAMP;
	prrection

Comments: