



FIRE DEPARTMENT

PLAN REVIEW CONDITIONS

January 05, 2017

GALE COMMUNITIES INC
400 SW LONGVIEW BLVD STE 105
LEES SUMMIT, MO 64081

Permit No: PRCOM20170010
Project Title: PROGRESSIVE AUTO INSURANCE
Project Address: 400 SW LONGVIEW BLVD, Unit:125, LEES SUMMIT, MO 64081
Parcel Number: 62420150101000000
Location: TOWER PARK COMMERCIAL-PHASE 2---PT LOT 3 DAF: BEG NW COR SD LOT TH N 47 DEG 47 MIN 39 SEC 21.38' TH NELY ALG CURV LF RAD 340' DIST 191.77' TH N 58 DEG 46 MIN 33 SEC E 74.75' TH S 76 DEG 13 MIN 27 SEC E 63.64' TH S 31 DEG 13 MIN 27 SEC E 185.25' TH S 58 DEG 46 MIN 33 SEC W 157' MOL TH N 63 DEG 48 MIN 07 SEC W 146' MOL TH N 86 DEG 44 MIN 52 SEC W 172.98' TH N 03 DEG 15 MIN 08 SEC E 97.29' TO POB
Type of Work: ALTERATION COMMERCIAL
Occupancy Group:
Description: REMOVE 2 OFFICES FOR OPEN OFFICE SPACE

*drawings are in plan review file

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Joe Frogge

Approved

Fire Plan Review

Reviewed By: Joe Dir

Approved with Conditions

1. 2012 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions. HAVE THE CONTRACTOR PROVIDE SHOP DRAWINGS FOR ANY MODIFICATIONS TO BE DONE TO THE FIRE ALARM SYSTEM. (INFORMATION PURPOSES)

2. 2012 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

HAVE THE CONTRACTOR PROVIDE SHOP DRAWINGS FOR ANY MODIFICATIONS TO BE DONE TO THE FIRE SPRINKLER SYSTEM. (INFORMATION PURPOSES)

3. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

TESTING OF THE MODIFICATIONS DONE TO THE FIRE ALARM SYSTEM WILL BE REQUIRED PRIOR TO THE FINAL OCCUPANCY INSPECTION. TO SCHEDULE A TEST CONTACT THE FIRE DEPARTMENT AT 8126-969-1300. (INFORMATION PURPOSES)

4. 2012 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

THE EXISTING FIRE SPRINKLER SYSTEM SHALL BE CURRENT WITH ALL REQUIRED SERVICE AND MAINTENANCE. A CURRENT SERVICE TAG SHALL BE POSTED ON THE SYSTEMS RISER. (VERIFIED AT INSPECTION)

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.