

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161180, Building Permit - Commercial

Address: 501 NW SHAMROCK AVE, LEES SUMMIT, MO 64081521 NW SHAMROCK AVE, LEES SUMMIT,  
MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Concrete Walls and Columns Inspection</b>	John Borns	Partial	Friday, January 06, 2017

Partial Correction

1      Misc 1

**OK TO POUR WHEN READY C.I.P. CONCRETE WALL ON (0.0)  
FROM (A.7) TO (C.6);**

**CONSULT SPECIAL INSPECTOR RE POSSIBLE CENTERING OF #5  
"FLOATING" VERTICAL BARS.**

**Comments:**