

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20162108, Building Permit - Residential
Address: 1713 SW NAPA VALLEY DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Residential	Mark Harding	Passed	Monday, January 09, 2017

Gas Service Inspection - Residential	Mark Harding	Failed	Monday, January 09, 2017
---	--------------	--------	--------------------------

All Rough Inspection - Residential	Mark Harding	Failed	Monday, January 09, 2017
---	--------------	--------	--------------------------

Corrective Action Required

1	Misc 1	- install h2.5 clips per plans - collar tie over mstr closet and front bedroom, support ridge - block cantilever bsmt - low psi gas line - firestop garage chase, 2nd floor dead space.
---	--------	--

Comments: