

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRRES20162248, Building Permit - Residential  
Address: 1353 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection - Residential</b>	Khanh Nguyen	Passed	Monday, January 09, 2017
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Passed	Monday, January 09, 2017

### Comments:

-I APPROVED THE ELECTRICAL SERVICE; BUT FYI: KCPL DOES NOT WANT YOU TO DO ANY GROUNDING OR BONDING INSIDE THEIR METER BOX, SO THEY MIGHT NOT RELEASE THE METER. THIS IS THEIR POLICY. IF THEY FAIL THE SERVICE, THEN YOU NEED TO MOVE THE BONDING BUSHING TO THE SERVICE DISCONNECT SIDE.

-CHECK ON FINAL: COMPLETE ALL ELECTRICAL IN BASEMENT, ALL OUTSIDE ELECTRICAL SUCH AS LIGHTS AT EXTERIOR DOORS, RECEPTACLE AT REAR AND RECEPTACLE WITHIN 25 FT OF AC UNIT, FLOOD LIGHT, ETC