

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20152438, Building Permit - Commercial
Address: 3381 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	John Borns	Partial	Monday, January 09, 2017
Partial Correction 1 Misc 1		OK TO COVER WHEN READY L.G. STEEL FURRING FRAMING PER WALL SECTION 1/E1 ON ERECTION DRWG. TAPCON FASTENING APPROVED PER DETAIL 4/S4.01.	
Partial Correction 2 Misc 1		OK TO COVER WHEN READY FRAMING ONLY AT: SOUTH WALL OF 120 OK FOR CONSTRUCTION OF ADJACENT RAMP; RAISED FLOOR FRAMING AT 121-127; SAME AT 120; FRAMING OF PLATFORM AT CORRIDOR [128];	

Comments: