



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20152455	Date:	January 09, 2017
Project Title:	SUMMIT FAIR BUILDING E SHELL	Applicant:	
-	H & M		
Location:	820 NW BLUE PKWY, LEES SUMMIT, MO 64086	PROGRESSIVE ELECTRONICS INC 6102 ARLINGTON AVE RAYTOWN, MO 64133	
Type of Work:		Primary: (816) 765-5750	
Occupancy Group:	M		
Description:	NEW RETAIL BUILDING SHELL		
Construction Type:	Type IIB (Unprotected)		
Map Page:	195A		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Joe Dir

Rejected

1. Plans shall include entire shell building and tenant spaces
2. System must be able to communicate back to the Summit Fair's Shopping Centers main Fire Alarm Panel located in Building D 860 NW Blue Parkway.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.