

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20162083, Public Works Infrastructure Permit - Commercial

WATER UTILITIES FACILITY

Address: 1200 SE HAMBLER RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
PW-Water Line - Thrust Restraint	Brice Lawson	Partial	Tuesday, January 10, 2017

Informational

1 Brice Lawson 11/28/2016 10:59 AM

The thrust blocks have been installed on the fire line at the 22.5 degree bend at STA. 9+56.11, at the 90 degree bend at STA. 6+98.63, at the T, 90 degree bend and on the fire hydrant near STA. 6+50. KCMMB 5K mix was used for these thrust blocks.

Informational

2 Brice Lawson 11/29/2016 2:21 PM

The thrusts blocks were installed on the FH at STA. 10+04.99, the 22.5 degree bend at STA. 9+85.66.

Informational

3 Brice Lawson 11/30/2016 2:43 PM

The thrust blocks have been installed on the 8" T and the cap at STA. 2+88.86, the T for the 4" domestic and the T for the 6" fire line that are located near CI 30B.

Informational

4 Brice Lawson 01/10/2017 7:28 AM

On 1/9/17 She Digs It installed two straddle blocks with retainer glands on the existing 12" DI water main. These were installed in preparation for the relocation of this 12" water main.

Comments: