

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20162298, Building Permit - Residential
Address: 3913 NE TROON DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Tuesday, January 10, 2017

Corrective Action Required

1	Misc 1	-PROTECT PLUMBING AT MASTER SHOWER WALL -INSTALL STRAP AT OVERBORED TOP PLATES OF KITCHEN WALL; NAIL ALL STRAP HOLES AT LAUNDRY
---	--------	---

***OK TO INSULATE

Comments: