

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20162474, Building Permit - Commercial
Address: 415 SW JEFFERSON ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Partial	Tuesday, January 10, 2017

Partial Correction
1 Misc 1

NO ISSUES FOUND ON: INSTALLATION OF TRIPLE 2x10 CENTER BEAM, JOISTS AND 6x6 POSTS AT BASEMENT; RESTROOM WALL, WINDOW AND DOOR FRAMING AT UPPER LEVEL; 2x4 STUDS ADDED TO SOUTH KNEE WALL FRAMING AT ATTIC; **W4x13 HEADER OVER WEST ENTRANCE DOOR;**

NOTED SIX 6x6 WOOD COLUMNS AT BASEMENT SUBJECT TO APPROVAL WHEN APPROVED DRAWINGS ARE ON SITE.

Electrical Service Inspection - Commercial	John Borns	Partial	Tuesday, January 10, 2017
---	------------	---------	---------------------------

Corrective Action Required
1 Misc 1

SUPPLEMENTAL GROUND ROD CONNECTION NOT FOUND EXPOSED FOR INSPECTION

Comments: RELEASE ELECTRICAL SERVICE PENDING RE-INSPECTION OF SUPPLEMENTAL GROUND.