

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20170062, Building Permit - Residential
Address: 451 SE OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Mechanical Inspection - Residential	Mike Copeland	Failed	Wednesday, January 11, 2017

Corrective Action Required
1 Misc 1

B VENT CONNECTOR REQUIRED TO HAVE 1" CLEARANCE TO
COMBUSTABLE.

Comments: