

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160277, Building Permit - Commercial
Address: 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	John Borns	Partial	Wednesday, January 11, 2017

Partial Correction
1 Misc 1

LIGHT-GAUGE STEEL EXTERIOR WALL FRAMING SUBSTANTIALLY
COMPLETE WITH NO ISSUES FOUND AT: **NORTH ELEVATION;**
WEST ELEVATION; SOUTH ELEVATION;

Comments: