

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20162361, Building Permit - Commercial  
Address: 783 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Electrical Inspection - Commercial</b>	John Borns	Partial	Thursday, January 12, 2017

Partial Correction  
1          Misc 1

COPPER GROUNDING ELECTRODE CONDUCTORS CAD-WELDED  
TO UFER RE-BAR ELECTRODE JUMPERS AND EXTENDED TO  
OUTSIDE SLAB EDGE FORMS AT S.E. AND N.E. CORNERS

**Comments:**