

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20162362, Building Permit - Commercial
Address: 795 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Electrical Inspection - Commercial	John Borns	Partial	Thursday, January 12, 2017

Partial Correction
1 Misc 1

COPPER GROUNDING ELECTRODE CONDUCTORS CAD-WELDED
TO UFER RE-BAR ELECTRODE JUMPERS AND EXTENDED TO
OUTSIDE SLAB EDGE FORMS AT S.E. AND N.E. CORNERS

Comments: