

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20162474, Building Permit - Commercial  
Address: 415 SW JEFFERSON ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	John Borns	Partial	Thursday, January 12, 2017

Partial Correction  
1 Misc 1

NO ISSUES FOUND ON: INSTALLATION OF TRIPLE 2x10 CENTER BEAM, JOISTS AND 6x6 POSTS AT BASEMENT; RESTROOM WALL, WINDOW AND DOOR FRAMING AT UPPER LEVEL; 2x4 STUDS ADDED TO SOUTH KNEE WALL FRAMING AT ATTIC; W4x13 HEADER OVER WEST ENTRANCE DOOR; **SIX 6x6 WOOD COLUMNS AT BASEMENT;**

<b>Electrical Service Inspection - Commercial</b>	John Borns	Passed	Thursday, January 12, 2017
---	------------	--------	----------------------------

**Comments: G.E.C. FOUND TERMINATED AT GROUND ROD DRIVEN BELOW METER -- APPROVED.**