

**PLANNING AND CODES ADMINISTRATION DEPARTMENT**  
**220 SE GREEN STREET**  
**LEE'S SUMMIT, MO 64063**  
**(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161180, Building Permit - Commercial

Address: 521 NW SHAMROCK AVE, LEES SUMMIT, MO 64081501 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Foundation Inspection - Commerial</b>	John Borns	Partial	Thursday, January 12, 2017
Partial Correction 1        Misc 1		OK TO POUR WHEN READY PIT WALLS AT: SOUTH ELEVATOR @ F.8/11-12; <b>NORTH ELEVATOR PIT</b>	
Partial Correction 2        Misc 1		OK TO POUR WHEN READY FOUNDATION WALL ~8' LONG ON (13) PER SECTION 1/S3.4	
<b>Concrete Walls and Columns Inspection</b>	John Borns	Partial	Thursday, January 12, 2017
Partial Correction 1        Misc 1		OK TO POUR WHEN READY C.I.P. CONCRETE WALL ON (0.0) FROM (A.7) TO (C.6); <b>TO PRINT MARK (5) TO (6) TO (7);</b>  CONSULT SPECIAL INSPECTOR RE POSSIBLE CENTERING OF #5 "FLOATING" VERTICAL BARS.	
Partial Correction 2        Misc 1		OK TO POUR WHEN READY C.I.P. CONCRETE COLUMNS @ FOLLOWING LOCATIONS: <b>G/4;</b>	

**Comments:**