

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20152455, Building Permit - Commercial
Address: 820 NW BLUE PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	John Borns	Passed	Thursday, January 12, 2017

Comments: OK TO COVER WHEN READY LIGHT-GAUGE STEEL FRAMING FOR CORNICE AT B.1/8.3 TO B.1/9 TO 9/B.7