

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161426, Building Permit - Commercial
Address: 720 NW BLUE PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	John Borns	Partial	Thursday, January 12, 2017
Partial Correction 1 Misc 1		OK TO PRE-ROCK WHEN READY EXTERIOR WALLS WITH "Z" FURRING AND INSULATION @ SPACE 130 WEST WALL & @ 117 NW;	
Partial Correction 2 Misc 1		OK TO COVER WHEN READY LIGHT-GAUGE STEEL FRAMING AT OUTER EDGE OF NORTH ENTRANCE CANOPY	

Comments: