

---

**PUBLIC WORKS ENGINEERING DIVISION**

## **Inspection Summary**

---

Permit #: PRPWFC20162134, Public Works Infrastructure Permit - Commercial  
HT SOLUTIONS

Address: 1440 SE BROADWAY DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection Item:

| <b>Inspection:</b>               | <b>Inspector:</b> | <b>Outcome:</b> | <b>Date:</b>                     |
|----------------------------------|-------------------|-----------------|----------------------------------|
| PW-Water Line - Hydrostatic Test | Brice Lawson      | Passed          | Thursday,<br>January 12,<br>2017 |

Informational

- 1 Brice Lawson 01/12/2017 4:28 PM  
Mike's Site Work pressure tested the 6" fire line from the valve at the water main to the riser flange in the building. The pressure test passed.

**Comments:**

---