

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20151897, Building Permit - Commercial
Address: 1201 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Commercial	John Borns	Not Ready	Thursday, January 12, 2017

Corrective Action Required

1 Misc 1

GAS SUPPLY PIPING DRAWING INCOMPLETE. NO GAS PIPING SHOWN TO SWIMMING POOL EQUIPMENT.

Above Ceiling Inspection

John Borns

Partial

Thursday, January 12, 2017

Partial Correction

1 Misc 1

OK TO COVER WHEN READY SYSTEMS ABOVE LOWER GWB CEILINGS AT: 4TH FLOOR; 3RD FLOOR;

Comments: