

---

**PUBLIC WORKS ENGINEERING DIVISION**

## **Inspection Summary**

---

Permit #: PRRES20152714, Building Permit - Residential

Address: 249 SE COYLE DR, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection Item:

<b>Inspection:</b>	<b>Inspector:</b>	<b>Outcome:</b>	<b>Date:</b>
PW-Sidewalk Inspection	Tom Chandler	Partial	Wednesday, June 15, 2016

Corrective Action Required

- 1 Tom Chandler 06/15/2016 11:06 AM The sidewalk does not meet ADA guidelines. Will add the ADA ramp at a later time. Inspected forms only for the sidewalk from driveway to existing sidewalk and 2 panels past driveway. That section is in compliance and ready for concrete.

**Comments:**

---