

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161179, Building Permit - Commercial  
Address: 1820 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Framing Inspection - Commercial</b>	John Borns	Not Ready	Tuesday, January 17, 2017

Partial Correction  
1 Misc 1

OK TO COVER WITH BUILDING WRAP: SOUTH ELEVATION; WEST  
ELEVATION;  
CORRECTIONS IN PROGRESS AT NORTH ELEVATION

Corrective Action Required  
2 Misc 1

HIGH PERCENTAGE OF OVER-DRIVEN NAILS -- TO BE CORRECTED  
ON SUBSEQUENT WORK.

**GROUND CONDITIONS TOO WET/SLICK FOR LIFT TO TRAVERSE  
NORTH SIDE OF BUILDING**

**Comments:**