



**LEE'S SUMMIT**  
**MISSOURI**



---

**FIRE DEPARTMENT**

**PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20152455	Date:	January 17, 2017
Project Title:	SUMMIT FAIR BUILDING E SHELL - H & M	Applicant:	
Location:	820 NW BLUE PKWY, LEES SUMMIT, MO 64086	PROGRESSIVE CASUALTY INSURANCE P O BOX 89429 CLEVELAND, OH 44101	
Type of Work:			
Occupancy Group:	M	PROGRESSIVE ELECTRONICS INC	
Description:	NEW RETAIL BUILDING SHELL	6102 ARLINGTON AVE RAYTOWN, MO 64133	
Construction Type:	Type IIB (Unprotected)		
Map Page:	195A	Primary: (816) 765-5750	

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

**Alarm Plan Review**

**Reviewed By: Joe Dir**

**Rejected**

1. Plans shall include entire shell building and tenant spaces. FACP to be located in the landlord room located behind the tenant spaces. Make reference to the YAEGER Architecture drawings for the location of the landlord room and additional future tenant spaces.
2. System must be able to communicate back to the Summit Fair's shopping centers main Fire alarm Panel located in building D 860 NW blue Parkway.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**